

Emission Test Certificate

Tuesday, August 30th, 2016

Supplier: Floor Distributors (PO Box 197 Neutral Bay Junction, NSW 2089)

Sample Description: Balmain Oak Floorboard

Date Tested: August 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia <i>Green Star Interiors V1.1 - 12.1 & 12.2</i> <i>Green Star Design & As Built V1.1 - 13.1 & 13.2</i></p>	<p>Balmain Oak Floorboard</p>
<p>Total Volatile Organic Compound Emission Rate limit <0.5mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.010mg/m²/hr</p>
<p>4-phenylcyclohexene Emission Rate limit <0.05mg/m²/hr</p>	<p>4-phenylcyclohexene Emission Rate: <0.004mg/m²/hr</p>
<p>Formaldehyde Emission Rate limit <0.1mg/m²/hr</p>	<p>Formaldehyde Emission Rate: 0.030mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

CV160819