

Emission Test Certificate

Friday, September 02nd, 2016

Supplier: Floor Distributors (PO Box 197 Neutral Bay Junction, NSW 2089)

Sample Description: Balmain Oak Floorboard

Date Tested: August 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia <i>Green Star Interiors V1.1 - 12.1 & 12.2</i> <i>Green Star Design & As Built V1.1 - 13.1 & 13.2</i></p>	<p>Balmain Oak Floorboard</p>
<p>Total Volatile Organic Compound Emission Rate limit <0.5mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.01 mg/m²/hr</p>
<p>4-phenylcyclohexene Emission Rate limit <0.05mg/m²/hr</p>	<p>4-phenylcyclohexene Emission Rate: <0.004 mg/m²/hr</p>
<p>EN 13968</p>	<p>Balmain Oak Floorboard</p>
<p>Formaldehyde Emission limit for E1 classification: ≤0.1 ppm</p>	<p>Formaldehyde Emission: 0.014 ppm* (Formaldehyde Emission Class E1)</p>

*Standard EN 13968 references test method EN 717-1 for the limit of ≤0.1ppm of class E1. The stated result was calculated from an emission rate applied to the Greenguard Standard Office Model using 13m² exposed floor area, room volume of 32m³, ventilation rate of 0.72 hr⁻¹.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
B.E Chem.
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160819a