

# Fire Test Certificate

Tuesday, September 13<sup>th</sup>, 2017

Supplier: Floor Distributors (719 The Horsley Drive, Smithfield, NSW 2164)

Sample Description: Viva Hybrid Plank Flooring

Date Tested: September 2017 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

<b>ASISO 9239-1:2003</b>	<b>Viva Hybrid Plank Flooring</b>
<b>Critical Heat Flux/Critical Radiant Flux*</b>	8.7 kW/m <sup>2</sup>
<b>Smoke Value*</b>	78 %.min
<b>Blistering</b>	Yes
<b>Melting</b>	Yes
<b>Glowing</b>	N/A
<b>Smoldering</b>	N/A

\*Three test average value



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B Eng (Chem)  
Consultant

**CV170842A**