

Fire Test Certificate

Monday December 7th, 2015

Supplier: Floor Distributors (PO Box 197 Neutral Bay Junction, NSW 2089)

Sample Description: Balmain Oak Engineered Flooring

Date Tested: November 2015 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: ISO 9239-1:2010 Part 1: Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

ISO 9239-1:2010 Part 1	Balmain Oak Engineered Flooring
Critical Heat Flux/Critical Radiant Flux*	3.6 kW/m ²
Smoke Value*	37 %.min
Penetration of flame through to substrate	Yes
Glowing	Yes
Smoldering	Yes

*Three test average value



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng (Chem.)
Consultant

CV151026