

Dimensional Stability Test Certificate

Thursday 8th January 2026

Supplier: Floor Distributors Pty Ltd (719 The Horsley Drive, SMITHFIELD, NSW 2164, Australia).
Product name: VIVA LUXURY Vinyl Plank 4.5mm thickness.
Date Tested: 30th December 2025 (Tested by FORAY Laboratories Pty Ltd)
Test Method: ISO 2551-2020 "Determination of dimensional changes due to the effects of varied water and heat conditions and distortion out of plane".

Test Results:

Means Linear change when exposure to:	VIVA LUXURY Vinyl Plank 4.5mm
Heat at 60°C for 2 hours	Length: 0.10% Wide: -0.10%
Water at 20°C for 2 hours	Length: -0.00% Wide: 0.00%
Heat at 60°C for 24 hours	Length: -0.05% Wide: -0.20%
Standard atmosphere for 48 hours	Length: -0.00% Wide: -0.00%
Degree of Cockling observed	None
Negative sign denotes Shrinkage Reported to Nearest 0.05%	



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 8/01/2026

Expiry date: 8/01/2031

P25120142