

Emission Test Certificate

Thursday 22th February 2024

Supplier	Floor Distributors Pty Ltd (719 The Horsley Drive, SMITHFIELD, NSW 2164, Australia).
Product Name	Viva Luxury Vinyl Plank
Date Tested	February 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method	ASTM D5116-2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data (24 hrs):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.2	Viva Luxury Vinyl Plank
Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate: 0.043 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m ² /hr	Formaldehyde Emission rate: 0.010 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 22/2/2024

Expiry date: 22/2/2029

P24020011