

Fire & Smoke Test Certificate

Thursday November 19th, 2020

Supplier: Floor Distributors Pty Ltd (719 The Horsley Drive, Smithfield, NSW, 2164, Australia)

Sample Description: Viva Original Plank

Date Tested: 25th May 2020 (Tested by Laboratories – NATA Accreditation 1356)

Test Method: AS/ISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

AS/ISO 9239-1:2003	Viva Original Plank Flooring
Critical Heat Flux/Critical Radiant Flux*	≥ 11 kW/m ²
HF-30 Value*	Not reported as flame out time occurred before 30 min
Smoke Value (Smoke development rate-SDR)*	117 %.min
Melting	Yes

*Three test average value



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

V2011052