

# Emission Test Certificate

Monday March 2<sup>nd</sup>, 2020

Supplier: Floor Distributors Pty Ltd (719 The Horsley Drive, Smithfield, NSW, 2164, Australia)

Sample Description: Viva Classic Plank

Date Tested: February 2020 (Tested through FORAY Laboratories - NATA Accreditation 1231)

Test Method: ASTM D5116-17 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

**Emission Data (24 hrs exposure):**

<p><b>Green Building Council of Australia</b> Green Star Design &amp; As Built v1.3 13.1.2B &amp; 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p><b>Viva Classic Plank</b></p>
<p>Total Volatile Organic Compound Emission Rate limit: ≤0.5 mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.007 mg/m<sup>2</sup>/hr</p>
<p>Formaldehyde Emission Rate limit: ≤0.1 mg/m<sup>2</sup>/hr</p>	<p>Formaldehyde Emission Rate: &lt;0.005 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dale Duncan  
BSc(Hons)  
Consultant



Tuan Duong  
B Eng. (Chem.)  
Consultant

V2002076