

Wet Slip Test Certificate

Thursday September 7th, 2017

Supplier: Floor Distributors (PO Box 197 Neutral Bay Junction, NSW 2089)

Sample Description: Federation Plank

Date Tested: August 2017 (Tested through FORAY Laboratories)

Test Method: AS/NZS 4586-2004 Appendix A "Slip resistance classification of new pedestrian surface materials – Wet Pendulum Test Method" using a Four S slider (Slider 96)

Test Data:

Sample Identification	Wet floor friction result ¹	Classification ² (Standards Australia Handbook 197)
Federation Plank	35	P3

¹ Five test average value

² The classification indicates that the contribution of the floor surfaces to the risk of slipping when wet is moderate.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

CV170842